



Azadi Ka  
Amrit Mahotsav



GOVT OF ASSAM  
OFFICE OF THE JOINT DIRECTOR OF HEALTH SERVICES  
LAKHIMPUR ::: NORTH LAKHIMPUR

Dist Ph. No. 03752222291

E-Mail- jtdhs.lakhimpur.hs001@gmail.com


No. JDH/PH.Cert/2024/66


Dated North Lakhimpur, the 3<sup>rd</sup> 9<sup>th</sup> Jan/24


Certificate of safe Drinking Water Sanitation and Hygienic Certificate

Certified that we have inspected Gyan Educational Institution, Kathoni Road, Harmutty, Assam, and we found that the school Authority is maintaining proper sanitation condition in the Institution and separate toilets for Boys and Girls are available. There is adequate availability of drinking water in the school.

The above certificate is valid w.e.f 03.01.2024 to 03.01.2025.

  
(Dr. Dhiren Saikia)  
S.D.M. & H.O. (PH)  
J.D.H.S. (N.L.)  
Lakhimpur, North Lakhimpur.

  
Secretary / Principal  
Gyan Educational Society  
Kathoni Road, Harmutty  
Dist. Lakhimpur, Assam

  
Principal  
Gyan Educational Institution  
Kathoni Road, Harmutty

OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER (PHE)  
BIHPURIA SUB-DIVISION, BIHPURIA.

WATER SAMPLE ANALYSIS REPORT

1. Laboratory Ref. No. :-1423/2023
2. Name Of Pin-Point Location:- GYAN EDUCATIONAL INSTITUTION.
3. Block:- Karunabari G.P:- Harmutty Vill:- Harmutty.
4. Type Of Source : Ring Well (Filter Water)
5. Depth Of Source:-
6. Geo-tag Latitude& Longitude:-
7. Date of collection:- 23/04/2024
8. Sample collector:- Sanjay Shah.
9. Date of received:-23/04/2024
10. Name of the sender :- Sanjay Shah.
11. Date of examination:- 24/04/2024

PHYSICAL CHARACTERISTICS

| Sl. No. | Parameter | Permissible limit | Result |        |
|---------|-----------|-------------------|--------|--------|
|         |           |                   | Raw    | Filter |
| 1       | COLOUR    |                   |        | Clear  |
| 2       | ODOUR     |                   |        | Free   |
| 3       | TURBIDITY | 5 NTU             |        | 0 NTU  |


CHEMICAL CHARACTERISTICS

| Sl. No. | Parameter              | Desirable limit/Permissible limit | Result |        |
|---------|------------------------|-----------------------------------|--------|--------|
|         |                        |                                   | Raw    | Filter |
| 1       | PH Value               | 6.5-8.5                           |        | 6.55   |
| 2       | NITRATE                | 0-45                              |        | 1.56   |
| 3       | HARDNESS               | 300-600                           |        | 140    |
| 4       | CHLORIDE               | 250-1000                          |        | 10.21  |
| 5       | FLOURIDE               | 1.0-1.5                           |        | 0.22   |
| 6       | RESIDUAL CHLORINE      | 0.2-1.0                           |        | 0.00   |
| 7       | IRON                   | 0.3-1.0                           |        | 0.25   |
| 8       | ARSENIC                | 0.00-0.01                         |        | 0.000  |
| 9       | TOTAL DISSOLVED SOLIDS | 500-2000                          |        | 132    |
| 10      | Alkalinity             | 200-600                           |        | 90     |

Remarks :- 1. As per the given Filter Water Sample, It is Fit.

2. The Report valid for Three(3) month.

  
Nodal Officer(PHE)  
BIHPURIA SDLL  
Nodal Officer  
Bihpuria SDLL

  
Assistant Chemist,(PHE)  
BIHPURIA,SDLL  
ASSISTANT CHEMIST  
Bihpuria (PHE) SDLL  
Bihpuria